

# IMPORTANT!

THIS DEVICE MUST BE INSTALLED BY A QUALIFIED PERSON WHO UNDERSTANDS ELECTRICAL CIRCUITS.

Please read all the information on this sheet.

# WARNING

A Ground Fault Circuit Interrupter (GFCI) is an electrical safety device that under normal use is intended to mitigate electric shock hazard. Use this product only within the specified operating parameters. (Failure to do so may result in bodily injury.) Consult a licensed electrician for assistance on installation and repairs. Do not use this GFCI if it fails to function as instructed. Never attempt to tamper with this device. This GFCI must never be used as a switch to connect or disconnect power. (Power should be disconnected at main power feed or by secondary switch located at the primary feed of GFCI.) This GFCI is not an over-current protection device. (An appropriate fuse or circuit breaker must be used in series at primary power feed.) This GFCI does not provide protection against shocks caused by holding both circuit conductors. This GFCI does not provide protection against electrical shocks generated by the conductors supplying power to the device. Note: primary feed to GFCI is live even when GFCI is tripped. (Power should be disconnected at main service panel before servicing load side of GFCI.)

- Do not use this device to feed power to life support apparatus.
- To minimize nuisance tripping:
  - Do not use on swimming pool equipment installed before 1965 NEC code.
  - Do not use on electric clothes dryers or electric ranges with frames grounded by neutral conductor.
- Installation must comply with local and national electrical codes (NEC).
- During installation, turn power off at the service panel to prevent serious injuries.



North Shore Safety 7335 Production Drive Mentor, Ohio 44060 Phone: 440.205.9188 Fax: 440.205.9187 Toll-free: 877.472.3348 Web: www.nssltd.com Email: sales@nssltd.com

## What is a GFCI?

A GFCI is a device designed to interrupt power when a ground fault (a current that takes a path to ground) exceeds a predetermined value. This power interruption is quickly accomplished to prevent serious injuries.

### Why do we need a GFCI?

The human body is conductive to electricity, and electric shocks can be fatal. Any electrical tool or appliance is a potential shock hazard, especially when used near wet locations; and this is where a GFCI is needed the most. This is why most electrical codes require GFCI protection in kitchens, bathrooms, garages, outdoor outlets, laundry rooms, workshops, etc.

North Shore Safety's GFCI, LineGard®, will offer such pro tection. Its safety scope surpasses its peers to include open supply protection (most receptacle type GFCIs do not sense open neutral condition) as well as dual indication of operating modes, with fault indication or power status.

#### How does a GFCI operate?

The GFCI constantly monitors the current-balance of the conductors supplying power to the load. When a ground fault occurs - by a leakage or by shock - the imbalance of current is sensed and the GFCI trips when the ground fault exceeds 5 mA +/- 1 mA. The tripping action must be within a fraction of a second to prevent serious injuries.

#### What a GFCI cannot do:

- Will not protect the circuit's line side.
- Will not protect you when touching two current carrying conductors of opposite polarity (the GFCI sees this as a load).
- Will not protect you when touching a line of another circuit.
- Will not detect overcurrent.

# North Shore Safety TWO YEAR LIMITED MANUFACTURER'S WARRANTY

North Shore Safety warrants to the consumer its Line-Gard Ground Fault Circuit Interrupter (GFCI) to be free from defects in materials and workmanship, under normal use and service, for a period of two years from date of purchase. North Shore Safety, at its option, will repair or replace the defective GFCI without charge within 2-years of the date of the product's purchase provided that the defect occurred during normal use. The defective unit must be returned freight prepaid, with a RGA (Returned Goods Authorization) including a description of the problem, and a proof of purchase date to the Quality Assurance Dept. North Shore Safety, Ltd. 7335 Production Drive, Mentor, OH 44060.

North Shore Safety will not be liable, directly or indirectly, for installation or removal of this device, or for any personal injury, or property damages, or incidental, indirect, or consequential damages of any kind, as a result of a defective device. The exclusive remedy, under this warranty, is the repair or replacement of the defective device. In no case shall North Shore Safety's liability exceed the purchase price. This warranty is void or not covered if this device is found to be: not properly installed, tampered with, not used according to label instructions and ratings, enclosure breached (button cover label, conduit hubs, vent, or lid fasteners), surged, short circuited, or abused.

# INSTALLATION PROCEDURE:

# **DANGER: HAZARD OF ELECTRICAL SHOCK, BURN, OR EXPLOSION.** Disconnect power at main panel before you start the installation. **Failure to do so will cause severe shock, personal injury or death.**

#### **IMPORTANT:**

- 1. Read all the instructions in this leaflet and on the device label.
- 2. Identify all the features and wires (see drawings below or on next page).
- 3. Identify Line wires (solid color) and Load wires (with stripes).
- 4. Verify that the ratings on the device match your field line ratings.
- 5. Disconnect power at main panel.
- 6. Determine GFCI location and drill mounting holes using template provided.
- 7. Strip wires to 5/8".
- 8. Feed wires into junction box through appropriate hole and secure cable or conduit end of GFCI to junction box.
- 9. Choose the right wiring application and connect wires according to the drawings and instructions below or on the next page.
- 10. Secure GFCI box to mounting panel.
- 11. NOTE: ALL WIRE CONNECTIONS SHOULD BE MADE WITH APPROPRIATE RATED WIRE CONNECTORS.

# Permanent 30A Single and Split Phase Series



\*\* Ground wire is connected externally. Ground wire does not enter or exit the GFCI box. Although GFCI does not require Ground to operate, Ground connection is recommended and should be made at junction box.



## Permanent 30A Three Phase Series



\*\* **Ground wire is connected externally.** Ground wire does not enter or exit the GFCI box. Although GFCI does not require Ground to operate, Ground connection is recommended and should be made at junction box.



# **Testing Procedure**

#### **TEST PROCEDURE:**

Restore the power to the GFCI.

Press and release RESET button, Green Light (Power) should turn ON. (For Auto Power-Up model, Green Light will automatically turn on when power is initiated or restored.) Press Test button, Green Light (Power) turns off and Red Blinking Light (Fault) turns on.

#### CHECKING FOR CORRECT WIRING:

If GFCI is wired to protect a receptacle, plug a lamp into the protected receptacle. Press and release the RESET button, lamp should turn on. Press the TEST button. Lamp should turn off. If lamp stays on when pressing the TEST button, or if lamp does not light when pressing RESET button, turn main power off, check and correct your wiring connections. Repeat steps 1-4. If problem persists, DO NOT USE THIS GFCI. Consult a qualified electrician for assistance or replacement.

If GFCI is wired to protect equipment, press and release RESET button. Verify that the equipment power is on. Press TEST button. Equipment power should turn off. If equipment power does not come on when pressing and releasing RESET button, or if power stays on when pressing TEST button, turn main power off, check and correct your wiring connections. Repeat steps 1-4. If problem persist, DO NOT USE THIS GFCI. Consult a qualified electrician for assistance or replacement.

Always consult qualified electricians.

Technical Support:

+1(440) 205-9188 support@nssltd.com

# **Specifications**

#### TECHNICAL:

Rated Voltage:

Operating Voltage Range: Current: Frequency: Trip Level: Phase: Response Time: Dielectric Withstand:

Surge Withstand: Operating Temperature range: Leakage Current @ 93% Humidity: Overload Current: RF Noise Susceptibility:

Let go Line Voltage: Grounded Neutral Detection:

#### GENERAL:

- Construction: Type: Power-Up Type \*: Endurance: Open Neutral Protection: Grounded Neutral Protection: Power ON Indication: Power FAULT Indication:
- Enclosure Mounting Type: Wiring Application: Wiring Connections: Switch Interface Latching Mechanism: False trip due to impact: Agency Approval

## **IMPORTANT NOTE:**

\*Manual configuration should be specified when automatic power-up would create an unsafe condition after restoration of circuit power.

3Ø, 120/208VAC 3Ø, 120/240VAC Split Ø 85% to 110% of rated Up to 30 Amps or Wiring Device Rating 60 Hz, (50Hz available non-U.L.) 5 +/- 1mA Single, Split Phase, and Three Phase 25 mS max @500 Ohm Fault. 1500 VRMS across contact 4000 VRMS between conductors and enclosure Up to twenty 4kV/2kA impulses, per IEC 61000-4-5 -35°C to +66°C Zero 180 Amps, 50% Inductive (25 cycles) Normal Operation with 0.5 VRMS injected on power line with Frequencies up to 450 MHz 60% of Rated 2 Ohms or less (on applicable models only)

120VAC 1Ø, 208VAC 1Ø, 240VAC 1Ø, 277 VAC 1Ø (Not Listed), 240VAC 3Ø, 208VAC

Industrial Grade Design Class A Auto or Manual 3000 Operations Minimum at Rated Load Trip Upon Loss of Neutral (on applicable models only) Trips if Ground and Neutral touch at load side (on applicable models only) Lighted Green LED Blinking Red LED, plus Optional Annunciator or AC/DC Outputs (on applicable models only) NEMA 4X/6P Panel, Surface and Portable 3,4,5 Wire Single, Split, and 3-Phase Permanent (fixed mount) (see wiring instructions) **Double Insulated** Electromagnetic None U.L., cU.L., and cCSAus (U.L.943 and CSAC22.2 No. 144) (277VAC non-U.L.)

## Permanent 30A Single and Split Phase



\*Decision table part number shown is a 240VAC, 1Ø, 30 AMP, Automatic reset, No output on fault with panel mounting

# Permanent 30A Three Phase



